



RADICI PIETRO INDUSTRIES & BRANDS
Via Cavalier Pietro Radici, 19
24026, Cazzano Sant'Andrea, Bergamo
ITALY

Your message - reference

-

our reference

PW/1774

Gent

2025-10-22

Certification report 24/1774

1. Description of the flooring:

Product family	Tufted broadloom carpet 100% polyamide Woven textile backing
Total mass	1140 g/m ² - 3460 g/m ²
Effective pile thickness	3.0 mm – 16.3 mm

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009)

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
C _{fl}	E _{fl}	heat flux ≥ 4.5 kW/m ²

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB



addressee	our reference	Gent	page
RADICI PIETRO INDUSTRIES & BRANDS	PW/1774	2025-10-22	2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a non-combustible substrate¹

Cfl - s1

Related commercial names to this product group	SYDNEY
The obtained classification is based on the next test reports	Centexbel: 19.00125.01 dd 2019-02-11 Centexbel: 19.00569.01, 02, 03, 04 dd 2019-02-22 Centexbel: 21.02738.01 dd 2021-06-14 Centexbel: 22.04763.01 dd 2022-09-19 Centexbel: 22.05031.01 dd 2022-10-17 Centexbel: 24.00358.01, 02, 03, 04 dd 2024-02-13
Validity of the certificate	2027-10-17



Petra Wittevrongel

Product Certifier

¹ End use substrates of classes A1 or A2-s1,d0 (ISO 13238:2010 § 5.2.2)